



EC Type Examination Certificate

No. CE 588591

The certificate is granted to:

**Suzhou Xujiang Fire Fighting Facility
Xukou Industrial Park
Suzhou
Jiangsu
215164
China**

In respect of:

Portable Powder Fire Extinguisher Bodies

On the basis of our examination under the requirements of Council Directive 97/23/EC Module B of the Pressure Equipment Directive, as transposed into UK law by the Pressure Equipment Regulations SI 1999 2001.

For and on behalf of BSI, a Notified Body for the above Directive (Notified Body Number 0086):

Gary Fenton, Global Assurance Director

First Issued: **29/11/2012**

Latest Issue: **29/11/2012**



EC Type Examination Certificate

No. CE 588591

Scope: MFZL Portable Powder Fire Extinguisher Bodies with the following characteristics;

Type	Model	PS (bar)	Size/Capacity	Drawing ref.	Application
Portable Powder Fire Extinguisher	MFZL	14	0.8 kg	PED-XJT-15	Body.
Portable Powder Fire Extinguisher	MFZL	14	1 kg	PED-XJT-01	Body.
Portable Powder Fire Extinguisher	MFZL	14	2kg	PED-XJT-02	Body.
Portable Powder Fire Extinguisher	MFZL	14	3 kg	PED-XJT-05	Body.
Portable Powder Fire Extinguisher	MFZL	14	3-4 kg	PED-XJT-13	Body.
Portable Powder Fire Extinguisher	MFZL	14	4 kg	PED-XJT-03	Body.
Portable Powder Fire Extinguisher	MFZL	14	6 kg	PED-XJT-04	Body.
Portable Powder Fire Extinguisher	MFZL	14	9 kg	PED-XJT-06	Body.

First Issued: **29/11/2012**

Latest Issue: **29/11/2012**

*raising standards worldwide*TM

Page 2 of 2



This certificate remains the property of The British Standards Institution and shall be returned immediately upon request. To check its validity telephone +44 (0)845 080 9000

Information and contact: BSI, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP. Tel: +44 845 080 9000. BSI Assurance UK Limited, registered in England under number 7805321, at 389 Chiswick High Road, London, W4 4AL, UK. A member of the BSI Group of Companies.